

## CAB100 CMS Industrial Cabinet Large Differential Pressure Cabinet

Please choose one attribute from each numbered category and add the corresponding mark to the grid on top of the table.  
 As a result configuration code for the Vaisala device is formed. Example of order code with typical settings:

CAB100 **B** 1 **N** 0 **N** 0 0 **M** **A** 0 **N** 1 **N**

**Selections in bold are included in the prices of the basic versions.**  
*Selections in italic are available at an extra price.*

		1	2	3	4	5	6	7	8	9	10	11	12	13
<b>Vaisala Industrial Cabinet Configuration</b>		<b>B</b>	<b>1</b>	<b>N</b>	<b>0</b>	<b>N</b>	<b>0</b>			<b>A</b>		<b>N</b>		<b>N</b>
<b>1. Cabinet size</b>	<b>Large</b>													
	600 x 500 x 200 (mm) / 23,6 x 19,7 x 7,9 (in)	<b>B</b>												
<b>2. Powering</b>	<b>Power supply</b>													
	110-240 VAC / 24 VDC		<b>1</b>											
				<b>N</b>										
					<b>0</b>									
						<b>N</b>								
							<b>0</b>							
<b>7. Differential Pressure +/- 60 Pa (PDT101-P4C) *</b>	<b>None</b>													<b>0</b>
	1 pcs Differential Pressure Measurement													1
	2 pcs Differential Pressure Measurement													2
	3 pcs Differential Pressure Measurement													3
	4 pcs Differential Pressure Measurement													4
	5 pcs Differential Pressure Measurement													5
	6 pcs Differential Pressure Measurement													6
	7 pcs Differential Pressure Measurement													7
	8 pcs Differential Pressure Measurement													8
	9 pcs Differential Pressure Measurement													9
	10 pcs Differential Pressure Measurement													A
	11 pcs Differential Pressure Measurement													B
	12 pcs Differential Pressure Measurement													C
<b>8. Differential Pressure +/- 0.25" H2O (PDT101-W4C) *</b>	<b>None</b>													<b>N</b>
	1 pcs Differential Pressure Measurement													A
	2 pcs Differential Pressure Measurement													B
	3 pcs Differential Pressure Measurement													C
	4 pcs Differential Pressure Measurement													D
	5 pcs Differential Pressure Measurement													E
	6 pcs Differential Pressure Measurement													F
	7 pcs Differential Pressure Measurement													G
	8 pcs Differential Pressure Measurement													H
	9 pcs Differential Pressure Measurement													J
	10 pcs Differential Pressure Measurement													K
	11 pcs Differential Pressure Measurement													L
	12 pcs Differential Pressure Measurement													M
<b>9. Communication</b>	<b>Port Server (DIGI TS4)</b>													<b>A</b>
	1 port Ethernet RJ-45 10/100 Mbps													
<b>10. Ethernet Switch</b>	<b>None</b>													<b>0</b>
	1 pcs Ethernet Switch													1
	To optionally add number of Ethernet ports from 1 to 5 pcs, RJ-45 10/100 Mbps (not used in standard installation)													
														<b>N</b>
<b>12. Housing Bottom Flange Material (Housing Top Flanges Rubber as standard)</b>	<b>Rubber flanges</b>													<b>1</b>
	2 x 25 ports (Multigate MC25) with cable clamp bars													
	<i>Stainless Steel Flanges</i>													<i>2</i>
	2 x 11 pcs EMC protected cable glands and 2 x 5 pcs optional ports													

\*Total maximum of 12 pcs differential pressure measurements per Large CAB100